

Ventilation Guidelines: Wine-mate Water Cooled Split System Units

Your cellar must be properly insulated and vapor sealed in order for these units to function properly. Place the unit in a properly ventilated location. If it is not, heat exhausted by the condensing unit will build up and the cooling system will not operate properly.

Model Number		
WM-2500SSDWC	WM-6500SSDWC	<p>Evaporator: Air supply shall be unobstructed minimum 12" for direct blow installation; leave a 2" clearance for a deflector installation; air return shall be unobstructed minimum 6".</p> <p>Please consult your unit's manual for more detailed clearance guidelines.</p>
WM-2500SSHWC	WM-6500SSHWC	
WM-2500SSLWC	WM-6500SSLWC	
WM-4500SSDWC	WM-8500SSDWC	
WM-4500SSHWC	WM-8500SSHWC	
WM-4500SSLWC	WM-2500SSRWC	
WM-6500SSDWC	WM-2500SSWWC	

*air supply shall be unobstructed minimum 12" for direct blow installation; leave a 2" clearance for a deflector installation; air return shall be unobstructed minimum 6".

